

Multi-machine Systems

- Each synchronous machine is represented by a constant voltage source behind the direct axis transient reactance
- The input powers are assumed to remain constant
- Using the pre-fault voltage, all loads are converted to equivalent admittances to ground and are assumed to remain constant
- Damping or asynchronous powers are ignored
- The mechanical rotor angle of each machine coincides with the electrical angle of the excitation voltage source

Modeling Steps

- Solve the initial load flow and obtain the initial bus voltage magnitude and phase angle
- Calculate the machine currents prior to the disturbance

$$I_{mach-i} = \frac{S_{mach-i}^*}{V_{mach-i}^*}$$

- Obtain the voltages behind the transient reactances

$$E'_{mach-i} = V_{mach-i} + j X'_d I_{mach-i}$$

- Convert all loads to equivalent admittances

$$y_{i0} = \frac{S_i^*}{|V_i|^2} = \frac{P_i - jQ_i}{|V_i|^2}$$

Modeling Steps

- Combine the generator models with the network's bus admittance matrix with converted loads

$$\begin{bmatrix} \mathbf{0} \\ \mathbf{I}_{mach} \end{bmatrix} = \begin{bmatrix} \mathbf{Y}_{nn} & \mathbf{Y}_{n-mach} \\ \mathbf{Y}_{n-mach}^T & \mathbf{Y}_{mach-mach} \end{bmatrix} \begin{bmatrix} \mathbf{V}_n \\ \mathbf{E}'_{mach} \end{bmatrix}$$

- Use kron reduction (matrix form) to remove the network buses from the matrix

$$\mathbf{Y}_{bus}^{reduced} = \mathbf{Y}_{mach-mach} - \mathbf{Y}_{n-mach}^T [\mathbf{Y}_{nn}]^{-1} \mathbf{Y}_{n-mach}$$

$$\mathbf{I}_{mach} = \mathbf{Y}_{bus}^{reduced} \mathbf{E}'_{mach}$$

Modeling Steps

- Express in terms of the machines' excitation voltages, the power output

$$S_{mach-i}^* = E_{mach-i}'^* I_{mach-i}$$

$$P_{mach-i} = \Re[E_{mach-i}'^* I_{mach-i}]$$

$$I_{mach-i} = \sum_{j=1}^m E_{mach-j}' Y_{ij}$$

$$P_{mach-i} = \sum_{j=1}^m |E_{mach-i}'| |E_{mach-j}'| |Y_{ij}| \cos(\theta_{ij} - \delta_i + \delta_j)$$

Multi-Machine Transient Stability

- Set initial conditions

$$P_{1-mach-i} = \sum_{j=1}^m |E'_{mach-i}| |E'_{mach-j}| |Y_{1-ij}| \cos(\theta_{ij} - \delta_i + \delta_j)$$

$$P_{e-i}(\delta) = P_{1-mach-i}$$

$$P_{m-i} = P_{e-i}(\delta)|_{t=0}$$

- Set machine inertia constants on a common system power base

$$H_i = \frac{S_{G-i}}{S_B} H_{G-mach-i}$$

Multi-Machine Transient Stability

- Solve the system of ODE's of the faulted network


$$\frac{H_i}{\pi f_0} \frac{d^2 \delta_i}{dt^2} = P_{mi} - \sum_{j=1}^m |E'_i| |E'_j| |Y_{2-ij}| \cos(\theta_{2-ij} - \delta_i + \delta_j)$$

- Solve the system of ODE's of the post-fault network

$$\frac{H_i}{\pi f_0} \frac{d^2 \delta_i}{dt^2} = P_{mi} - \sum_{j=1}^m |E'_i| |E'_j| |Y_{3-ij}| \cos(\theta_{3-ij} - \delta_i + \delta_j)$$

Example

- Consider the 3 machine system below
 - ◆ select generator #1 as the swing machine with a constant angle of 0 degrees
 - ◆ determine the system stability when a fault on the line 5-6 near bus 6 is cleared in 0.4 and 0.5 seconds



Example

- **Load Data**

| | P | Q |
|---|-----|-----|
| 1 | 0 | 0 |
| 2 | 0 | 0 |
| 3 | 0 | 0 |
| 4 | 1.0 | 0.7 |
| 5 | 0.9 | 0.3 |
| 6 | 1.6 | 1.1 |

- **Generator Data**


| | V | P |
|---|------|-----|
| 1 | 1.06 | --- |
| 2 | 1.04 | 1.5 |
| 3 | 1.03 | 1.0 |

- **Line Data**

| | R | X | $\frac{1}{2}B$ |
|-----|-------|-------|----------------|
| 1 4 | 0.035 | 0.225 | 0.0065 |
| 1 5 | 0.025 | 0.105 | 0.0045 |
| 1 6 | 0.040 | 0.215 | 0.0055 |
| 2 4 | 0.000 | 0.035 | 0.0000 |
| 3 5 | 0.000 | 0.042 | 0.0000 |
| 4 6 | 0.028 | 0.125 | 0.0035 |
| 5 6 | 0.026 | 0.175 | 0.0300 |

Example

**Power angle / time
fault clearing in 0.4 s**



Example

**Power angle / time
fault clearing in 0.5 s**

