


TEST (2) NEXT WEEK 30%

REVISION AFTER THE BREAK



CORONA



CORONA FORMS WHEN THE VOLTAGE OF A CONDUCTOR PASSES THE DISRUPTIVE CRITICAL VOLTAGE. THIS OCCURS ON EACH CONDUCTOR AT EVERY HALF CYCLE AND CONTRIBUTES A TRIPLE HARMONIC TO CHARGING CURRENT

DISRUPTIVE CRITICAL VOLTAGE

THE BREAK DOWN STRENGTH OF AIR AT 76 cm (PRESSURE) PRESSURE AND 25°C IS 30 KV/cm (OR) 21.1 KV (rms)/cm.



DIFFERENTIAL
HARMONIC
DISTORTION

$$\delta = \frac{3.92 b}{273 + T}$$

$$T = ^\circ C$$

b = THE HEIGHT OF MERCURY IN BAROMETER

r = RADIUS OF CONDUCTOR

D = DISTANCE BETWEEN CONDUCTORS

(GEOMETRIC MEAN DISTANCE)

$$E_g = m \delta g_b r \ln \frac{D}{r}$$

E_g = BREAK DOWN VOLTAGE TO GROUND (KV)

m = CONSTANT FOR SURFACE

m = 1.0 SMOOTH WIRE

0.93 WEATHERED WIRE


0.87 STRANDED WIRE

CORONA

CORONA FORMS WHEN THE VOLTAGE OF A CONDUCTOR PASSES THE DISRUPTIVE CRITICAL VOLTAGE. THIS OCCURS ON EACH CONDUCTOR AT EVERY HALF CYCLE AND CONTRIBUTES A TRIPLE HARMONIC TO THE CHARGING CURRENT.

DISRUPTIVE CRITICAL VOLTAGE

BREAK DOWN STRENGTH OF AIR AT 76 cm pressure
25°C IS 30 kV/cm (OR) 21.1 kV (RMS)/cm
(PEAK)




SPHERE TEST



$$\delta = \frac{3.92 b}{273 + T}$$

b = BAROMETRIC
PRESSURE OF
MERCURY



E_g = BREAK DOWN VOLTAGE TO NEUTRAL

$$E_g = m \delta g_b r L_n \frac{D}{r}$$


$$g_b = 21.1$$

r = RADIUS OF CONDUCTOR

m = 1.0 FOR SMOOTH WIRE


0.93 FOR ROUGHENED (OR) WEATHERED WIRE

0.87 STRANDED WIRE



$$\delta = \frac{3.92 b}{293 + T}$$

δ = BAROMETRIC
PRESSURE OF
MERCURY



E_g = BREAK DOWN VOLTAGE TO NEUTRAL

$$E_g = m \delta g_b r \ln \frac{D}{r}$$


$$g_b = 21.1$$

r = RADIUS OF CONDUCTOR

$m = 1.0$ FOR SMOOTH WIRE

0.93 FOR ROUGHENED (OR) WEATHERED

0.87 STRANDED WIRE




VISUAL CRITICAL VOLTAGE = $E_v = 21.1 m \delta r \left(1 + \frac{0.3}{\sqrt{\delta r}} \right) L m \frac{\Phi}{r}$

KV RMS
TO NEUTRAL

DISADVANTAGE OF CORONA

- POWER LOSS
- INTERFERENCE TO TELECOMMUNICATION SYSTEM.

AVOIDANCE OF CORONA



TO AVOID THE CORONA, THE DISTANCE BETWEEN CONDUCTOR NEEDS TO BE INCREASED TO INCREASE THE DISRUPTIVE CRITICAL VOLTAGE.

BUT SUCH . DISTANCE IS LIMITED BY COST.

IN PRACTICAL, HOLLOW CONDUCTORS ARE UTILIZED STEEL CORE , ALUMINIUM STRANDED

CONDUCTORS → INCREASE THE STRENGTH
→ REDUCE THE POSSIBILITY
FOR CORONA


TO AVOID THE CORONA, THE DISTANCE BETWEEN CONDUCTOR NEEDS TO BE INCREASED TO INCREASE THE DISRUPTIVE CRITICAL VOLTAGE.

BUT SUCH DISTANCE IS LIMITED BY COST.

IN PRACTICAL, HOLLOW CONDUCTORS ARE UTILIZED
STEEL CORE, ALUMINIUM STRANDED

CONDUCTORS → INCREASE THE STRENGTH
→ REDUCE THE POSSIBILITY
FOR CORONA

SHORT CIRCUIT CURRENT OF ALTERNATOR




$$i_{sc} = A e^{-\frac{Rt}{L}} + B$$

$$A = \frac{E}{\sqrt{R^2 + \omega^2 L^2}} \sin\left(\theta - \tan^{-1} \frac{\omega L}{R}\right)$$





$$B = \frac{E}{\sqrt{R^2 + \omega^2 L^2}} \sin\left(\omega t + \theta - \tan^{-1} \frac{\omega L}{R}\right)$$

$$\omega = 2\pi f$$

POWER FACTOR
ANGLE



CURRENT LIMITING REACTORS



$$X = \frac{(n-3)}{2n} \times G$$

$$n > 3$$

n = NUMBER OF SECTION

G = % INDUCTIVE REACTANCE
OF GENERATOR


X = % INDUCTIVE REACTANCE
OF REACTOR

VOLTAGE TRANSIENTS AND LINE SURGES

POWER LINE RESONANCE PRODUCES LINE VOLTAGE SURGE

$$X_L = 2\pi f L$$

$$X_C = \frac{1}{2\pi f c}$$



$$Z = \sqrt{R^2 + (X_L - X_C)^2}$$


AIR



300 Hz

$$f_r \rightarrow X_C = X_L$$




$Z = \text{MINIMUM}$



$$I = \frac{E}{Z} \rightarrow I = \text{MAX}$$

CAUSE OF LINE SURGE

- (1) RESONANCE
- (2) SWITCHING
- (3) INSULATION FAILURE
- (4) ARCING TO EARTH
- (5) LIGHTNING STRIKE



SWITCHING VOLTAGE

SWITCHING EMF VELOCITY :

$$v = \frac{1}{\sqrt{LC}}$$

LIGHT VELOCITY

3×10^{10} cm/s

L = INDUCTANCE

C = CAPACITANCE OF LINE

SWITCHING CURRENT

$$i = \frac{E}{\sqrt{C/L}} - \frac{E}{Z}$$

$$Z = \sqrt{\frac{L}{C}}$$

LINE IMPEDANCE


Z = SWITCHING IMPEDANCE

$$L = 4 \ln \frac{D}{r} \times 10^{-6} \text{ H/cm} \quad (\text{SURGE IMPEDANCE})$$

$$C = \frac{1}{4 \ln \frac{D}{r}} \text{ MF/cm}$$

400 → 600 Ω (OVERHEAD LINE)

40 → 600 Ω (CABLE)






LINE SURGE CAN DAMAGE THE EQUIPMENTS. THE NATURE OF SURGE

THE ORIGIN OF LINE SURGE AND PROTECTION SYSTEM NEEDS TO


APPLY IN POWER SYSTEM.

VOLTAGE SURGE & PROTECTION



- PROTECTION
- ARCING HORN
 - LIGHTNING ARRESTOR
 - SURGE ABSORBER

CALCULATION OF VOLTAGE SURGE



$$i = \frac{Z_B - Z_A}{Z_B + Z_A} i$$

$$E' = \frac{Z_B - Z_A}{Z_B + Z_A} E$$

$$Z = \text{NATURAL IMPEDANCE} = \sqrt{\frac{L}{C}}$$

E'' = MAXIMUM VOLTAGE AT JUNCTION

i'' = MAXIMUM CURRENT AT JUNCTION

E = REFLECTED CREST VOLTAGE

E = NORMAL SYSTEM VOLTAGE


$$E'' = E + E'$$

PROBLEM

A TRANSMISSION LINE HAS 0.0128 PF CAPACITANCE AND 1.5 MH INDUCTANCE. IT IS JOINED WITH A CABLE 0.34 PF CAPACITANCE AND 0.25 MH INDUCTANCE.

- NATURAL IMPEDANCE OF O.H LINE
- NATURAL IMPEDANCE OF U.G CABLE
- REFLECTED CREST VOLTAGE
- MAXIMUM VOLTAGE AT JUNCTION

$$\text{LINE VOLTAGE} = 50 \text{ kV}$$




$$(a) \text{ OH LINE } Z_B = \sqrt{\frac{L}{C}} = \sqrt{\frac{1.5 \times 10^{-3}}{0.0125 \times 10^{-6}}} = 346.4 \Omega$$

$$(b) \text{ UG CABLE } Z_A = \sqrt{\frac{L}{C}} = \sqrt{\frac{0.25 \times 10^{-3}}{0.3 \times 10^{-6}}} = 28.9 \Omega$$

$$(c) E' = \frac{Z_B - Z_A}{Z_B + Z_A} E = \frac{346.4 - 28.9}{346.4 + 28.9} \times 50 = 42.3 \text{ kV}$$

$$(d) E'' = E + E' \\ = 50 + 42.3 \\ = 92.3 \text{ kV}$$

REFLECTION AT JUNCTION



$$E' = E \frac{\left(\frac{1}{Z} - \frac{1}{Z_1} - \frac{1}{Z_2} \right)}{\frac{1}{Z} + \frac{1}{Z_1} + \frac{1}{Z_2}}$$


$$E'' = E + E'$$

$$i_1'' = \frac{E''}{Z_1}, \quad i_2'' = \frac{E''}{Z_2}$$

ph

10 KV LINE WITH 700Ω IS CONNECTED TO 100Ω AND 200Ω LINES.

CALCULATE (i) REFLECTED VOLTAGE (ii) MAXIMUM VOLTAGE AT JUNCTION
(iii) MAXIMUM CURRENTS IN BRANCH LINES AND MAIN LINE.



$$E' = \frac{E \left(\frac{1}{Z} - \frac{1}{Z_1} - \frac{1}{Z_2} \right)}{\frac{1}{Z} + \frac{1}{Z_1} + \frac{1}{Z_2}}$$

$$= \frac{10,000 \left(\frac{1}{700} - \frac{1}{100} - \frac{1}{200} \right)}{\frac{1}{700} + \frac{1}{100} + \frac{1}{200}}$$

$$E' = -8260V$$

$$E'' = E + E' = 10,000 + (-8260)$$

$$= 1740V$$

$$I_1 = \frac{E''}{Z_1} = \frac{1740}{100} = 17.4 \text{ Amp}$$

$$I_2 = \frac{E''}{Z_2} = \frac{1740}{200} = 8.7 \text{ Amp}$$

$$I = I_1 + I_2$$

$$= 17.4 + 8.7 = 26.1 \text{ Amp}$$

