


APPLICATION OF TELECOMMUNICATION SYSTEM IN POWER SYSTEM

TELECOMMUNICATION IS APPLIED IN POWER SYSTEM FOR POWER FLOW CONTROL, PROTECTION RELAYING.

TYPICAL TELECOM-BASED PROTECTION SYSTEM



THE LINE CURRENT / VOLTAGE IN POWER LINE IS SENSED BY
DETECTOR NETWORK THAT PRODUCES THE CONTROL SIGNAL.

THE TRANSMITTER SENDS THE CONTROL SIGNAL OVER
TELECOMM: CARRIER FREQUENCY.


THE RECEIVER OF THE OTHER SIDE OF THE LINE
ACCEPTS THE CONTROL SIGNAL AND FEEDS IT TO
THE COMPARATOR.

IN COMPARATOR, THE SIGNAL IS COMPARED WITH
REFERENCE AND SENT IN TO AUXILIARY TRIPPING
RELAY NETWORK THAT OPERATES CIRCUIT
BREAKER


HIGH FREQUENCY RADIO FREQUENCY

900 MHz


DIFFERENTIAL PROTECTION (TELECOM BASED)




EXTERNAL FAULT



(A) POINT
WAVE FORM
(VOLTAGE / CURRENT)




(B) POINT
WAVE FORM




PROBLEM

ON SYSTEM IN




INTERNAL FAULT




BLOCK - PREVENTING THE OPERATION

TRIP - MAKING THE OPERATION




NO OPERATION


A WAVE




B WAVE



A + B



FILTER



THE PROTECTIVE RELAYS TAKE RESPONSIBILITY FOR PROVIDING THE PROTECTION IN SPECIFIC LINE SECTION.

FOR EXAMPLE, IN LINE SECTION A - B, WHEN EXTERNAL FAULT OCCURS, THE WAVE FORMS AT A AND B POINTS CANCEL EACH OTHER'S TRIP SIGNALS. THERE IS NO RESULTANT TRIP SIGNAL.

WHEN INTERNAL FAULT OCCURS, THE TRIP SIGNALS OF THE WAVES ARE COMBINED TO OUTPUT THE RESULTANT TRIP SIGNAL THAT OPERATES THE PROTECTIVE RELAYS.

THOSE SIGNALS ARE PRODUCED BY TRANSDUCERS AND SENT TO STATION OVER TELECOM SYSTEM.

IN POWER LINE COMMUNICATION SYSTEM, BOTH CONTROL SIGNAL AND POWER VOLTAGE/CURRENTS ARE CARRIED BY THE SAME LINE.


CONTROL AND COMMUNICATION SIGNALS ARE INJECTED INTO THE LINE FROM MODULATOR THROUGH COUPLERS.

AT THE END OF THE LINE, THEY ARE PICKED UP


BY DEMODULATOR, TO FEED THE CONTROL DEVICES WHILE

POWER VOLTAGE AND CURRENT ARE SUPPLIED TO POWER

LOAD.




REMOTE AND COMPUTERISED CONTROL IN POWER SYSTEM



MICRO WAVE PILOT SYSTEM IS UTILIZED FOR POWER FLOW CONTROL.
ULTRA HIGH FREQUENCY ABOVE 900 MHz IS UTILIZED FOR CARRIER WAVE.

PHASE COMPARISON RELAYING BY REMOTE CONTROL SYSTEM



AT NORMAL CONDITION, THERE IS SPECIFIC VALUE FOR FLOW IN AND FLOW OUT CURRENT PHASE ANGLES.


T-TRANSM

R-RECEIV

SYSTEM

WHEN THE FAULT HAPPENS, THE PHASE ANGLES WILL BE DIFFERENT.

THE PHASE COMPARISON RELAY DETECTS THE PHASE AND IF ABNORMALITY IS DETECTED, THEN IT SUPERVISES THE PROTECTION CONTROL SYSTEM TO TRIP THE CIRCUIT BREAKER.



THE LINE CURRENTS ARE DETECTED BY CTS AND PHASE ANGLES ARE SENSED. SENSING IS DONE AT THE ENDS OF THE LINE FOR

A PARTICULAR LINE SECTION.

THE PHASE DETECTOR NETWORK PROVIDE THE RESULTS TO COMPARATOR.

THE COMPARATOR COMPARES THE QUANTITY WITH REFERENCE AND SUPERVISES THE TRIPPING CIRCUIT.

TELECOMMUNICATION SIGNAL WITH CARRIER FREQUENCY IS UTILIZED TO TRANSMIT THE SIGNAL.



T - TRANSMITTER, R - RECEIVER ARE UTILIZED TO TRANSMIT AND RECEIVING THE SIGNAL AT REMOTE SUBSTATION CONTROL CENTRE.

THE REASON TO PROVIDE THE PHASE
COMPARISON RELAYING IS





- (1) TO INCREASE THE SENSITIVITY
- (2) TO PROVIDE THE PROTECTION


FOR $L \rightarrow G$ FAULT
 $2L \rightarrow G$ FAULT

ETC.



DISCRIMINATING INTERNAL FAULT AND EXTERNAL FAULT IN TRANSMISSION LINE SECTION






WHEN EXTERNAL FAULT OCCURS, THE SIGNALS AT A AND B ARE SHOWN IN FIGURE.

WHILE A SIDE RELAY TRIES TO TRIP THE CIRCUIT BREAKER, B SIDE RELAY BLOCK (OPPOSES THE TRIPPING)

By combining two wave forms, the resultant wave has zero line and no relay operation takes place

When internal fault happens




When internal fault occurs, both A and B side transmitters send the signal to control station.

Two signals are in phase.


Tripping portions are combined.

By using filter to filter out the block portions, trip signal operates the circuit breaker to cut off the line.




DISTRIBUTED REAL TIME COMPUTER NETWORK ARCHITECTURE (DRNA) FOR POWER SYSTEM CONTROL

POWER STATION




SUPERVISORY
CONTROL PROGRAM
COMMUNICATION
MIDDLEWARE
PRIORITY SETTING

UTILIZED for Power flow / protection




EXECUTE THE TASK

ARRANGEMENT OF COMPUTERISED CONTROL & POWER NETWORK



THE OPERATION OF POWER GENERATION STATION AND REAL / REACTIVE POWER FLOWS ARE CONTROLLED BY COMPUTERS. THE COMPUTERS ARE CONNECTED ONE ANOTHER BY INTERNET / IP BASED TRANSPORT NETWORK.


Power Line Communication (PLC) system



TELECOM:
SIGNAL
FOR
CONTROL

(1)

SENDING
END




(HIGH VOLTAGE
HIGH CURRENT)
50 HZ

RECEIVING
END

THE SAME LINE CARRIES POWER FREQUENCY VOLTAGE
CURRENT AND TELECOMMUNICATION CONTROL SIGNAL
TELECOM: SIGNAL IS INJECTED INTO LINE BY MODULATOR
AND COUPLER.

AT THE END OF LINE, IT IS PICKED UP BY DEMODULATOR (MODEM)
AND SUPPLIED TO TELECOM / CONTROL EQUIPMENTS.




EXERCISE (10)

Q1 How is TELE COMMUNICATION SYSTEM APPLIED IN POWER SYSTEM?

TELE COMMUNICATION SYSTEM IS UTILIZED TO CONTROL PROTECTIVE RELAYS AND TO CONTROL POWER FLOW IN POWER SYSTEM.

TELE COM: SIGNALS RANGING ABOUT 900 MHz IS APPLIED.



FOR PROTECTION, PHASE COMPARISON RELAYING METHOD IS UTILIZED.

TELE COM: SIGNAL IS ALSO UTILIZED TO CONTROL ACTIVE AND REACTIVE POWER FLOW AT SUBSTATION.

IED - ARE UTILIZED TO INTER FACE TELE COM: LINE / POWER SYSTEM WITH COMPUTERS.

COMPUTERS ARE LINKED ONE ANOTHER BY IP BASED NETWORK.

POWER LINE COMMUNICATION SYSTEM IS APPLIED TO TRANSMIT BOTH ELECTRICAL POWER AND TELECOMM: SIGNAL ON THE SAME LINE.

PLC SIGNAL


50 Hz → 500 kHz → CONTROL EQUIPMENT / RELAYS → NO RADIO INTERFERENCE
 1 MHz → 30 MHz → COMMUNICATION CIRCUIT → SUBJECT TO RADIO INTERFERENCE

TYPE OF PROTECTIVE SCHEME


DIRECT TT - DIRECT TRANSFER TRIP

PERMISSIVE — OVER REACHING — TRANSFER TRIP
 UNDER REACHING — ALLOW THE SIGNAL TO PASS THROUGH






Blocking





COMPONENT OF ELECTRONIC CONTROL SYSTEM FOR POWER LINE




DIGITAL SIGNAL PROCESSING SUB SYSTEM FOR COMPUTER CONTROL POWER SYSTEM OPERATION




DIGITAL → ANALOG





DIGITAL SIGNAL PROCESSING SUBSYSTEM FOR COMPUTER CONTROL POWER SYSTEM OPERATION



COMPUTER
CONTROL
PROGRAM
FLOW
CHART




TYPICAL PROTECTION SCHEME




Computer flow chart for power system protection

HARDWARE



SIGNAL CONDITIONING SUB SYSTEM

CONVERSION SUBSYSTEM



SOFTWARE


Computer program for
Computerized power system
protection program

A/D - ANALOG → DIGITAL CONVERTER

D/A - DIGITAL → ANALOG CONVERTER

D/O - DATA OUTPUT

D/I - DATA INPUT



ELECTRONIC CONTROL SYSTEM FOR POWER SYSTEM

