



## BASIC METERING ARRANGEMENT IN SUBSTATION




LOCATION OF CURRENT TRANSFORMERS IN POWER SYSTEM



THE OVER CURRENT RELAYS ARE ALLOCATED AT LINE SECTIONS. THEY PROVIDE THE PROTECTION FOR THE SECTIONS OF THE LINE.

# POWER SURGE PROTECTION FOR TRANSMISSION LINE

ARCING HORN, LIGHTNING ARRESTER, SURGE ABSORBER




LIGHTNING STRIKE NEAR POWER TRANSFORMER IS PROTECTED BY ARCING HORN.

LIGHTNING ARRESTERS PROVIDE THE LIGHTNING PROTECTION FOR POWER LINE.

WHEN POWER SURGE OCCURS DUE TO SWITCHING OR UNBALANCED VOLTAGE, SURGE ABSORBER ABSORBS IT.

## GROUNDING IN POWER SYSTEM



BASIC IMPULSE INSULATION LEVEL FOR ELECTRICAL EQUIPMENTS (BIL)

TRANSFORMER INSULATION SHOULD WITHSTAND

THE HIGH VOLTAGE FOR A SMALL PERIOD

DURING WHICH THE LIGHTNING ARRESTER


DIRECTS THE SURGE VOLTAGE INTO GROUND

60Hz BIL = 46kV RMS


(OR)

65kV (PEAK)


## LOWER GROUNDING



$\Delta / \Delta$  GROUNDING TRANSFORMER



## GROUNDING IN POWER SYSTEM



BASIC IMPULSE INSULATION LEVEL FOR ELECTRICAL EQUIPMENTS (BIL)

TRANSFORMER INSULATION SHOULD WITHSTAND


THE HIGH VOLTAGE FOR A SMALL PERIOD

DURING WHICH THE LIGHTNING ARRESTER


DIVERTS THE SURGE VOLTAGE INTO GROUND

60 Hz BIL = 46 kV RMS  
(OR)  
66 kV (PEAK)

## LOWER GROUNDING



Δ / Z GROUNDING TRANSFORMER





$$P_T = P_1 + P_2 + P_3$$


Q9 A source given by

$e = 50 \sin \omega t + 20 \sin (3\omega t + 30^\circ) + 10 \sin (5\omega t - 90^\circ)$  VOLT is applied to a circuit and the resulting current is given by

$i = 0.5 \sin (\omega t - 39^\circ) + 0.1 \sin (3\omega t - 15^\circ) + 0.09 \sin (5\omega t - 150^\circ)$  AMP

FIND THE TOTAL POWER APPLIED AND OVER ALL POWER FACTOR.


Source voltage



$$P_1 = \frac{V_{1m} I_{1m}}{2} \cos 0^\circ$$

$$= \frac{50 \times 0.5}{2} \cos 39^\circ$$

$$= 10 \text{ W}$$




$$P_3 = \frac{V_{3m} I_{3m}}{2} \cos 0^\circ$$

$$= \frac{20 \times 0.1}{2} \cos 45^\circ$$

$$= 0.707 \text{ W}$$

5th harmonic



$$P_5 = \frac{V_{5m} I_{5m}}{2} \cos 0^\circ$$

$$= \frac{10 \times 0.09}{2} \cos 90^\circ$$


$$= 0.23 \text{ W}$$

$$P_T = P_1 + P_3 + P_5 = 10 + 0.707 + 0.23 = 10.9 \text{ W}$$

$$V = \sqrt{\frac{V_{1m}^2 + V_{3m}^2 + V_{5m}^2}{2}} = \sqrt{\frac{50^2 + 20^2 + 10^2}{2}} = 38.8 \text{ V}$$

$$i = \sqrt{\frac{I_{1m}^2 + I_{3m}^2 + I_{5m}^2}{2}} = \sqrt{\frac{0.5^2 + 0.1^2 + 0.09^2}{2}} = 0.365 \text{ amp}$$

$$VI = 38.8 \times 0.365 = 14.142 \text{ VA}$$



$$PF = \cos 0^\circ = \frac{10.9}{14.142} = 0.77$$

# EFFECTIVE VALUE OF DISTORTED WAVE

$E_H$  = EFFECTIVE VALUE OF HARMONICS VOLTAGE

$E_F$  = EFFECTIVE VALUE OF FUNDAMENTAL VOLTAGE

$E$  = EFFECTIVE VALUE OF DISTORTED VOLTAGE

$$E^2 = E_F^2 + E_H^2$$

$$E = \sqrt{E_F^2 + E_H^2}$$

$$\text{TOTAL HARMONIC DISTORTION (THD)} = \frac{E_H}{E_F}$$


ph

A SQUARE WAVE HAS AN AMPLITUDE OF 66V. THE FUNDAMENTAL IS 84V.


CALCULATE (a) THE EFFECTIVE VALUE OF SQUARE WAVE

(b) EFFECTIVE VALUE OF FUNDAMENTAL


(c) TOTAL HARMONIC DISTORTION




(E) = EFFECTIVE VALUE = 66V



ACTUAL



EFFECTIVE



EFFECTIVE

$$E_F = \frac{E_{MAX}}{\sqrt{2}} = \frac{84}{\sqrt{2}} = 59.4V$$

$$E^2 = E_F^2 + E_H^2$$

$$66^2 = 59.4^2 + E_H^2$$

$$E_H = \sqrt{66^2 - 59.4^2} = 28.8V$$

$$THD = \frac{E_H}{E_F} = \frac{28.8}{59.4} = 0.48$$

# EFFECTIVE VALUE OF DISTORTED WAVE

$E_H$  = EFFECTIVE VALUE OF HARMONICS VOLTAGE

$E_F$  = EFFECTIVE VALUE OF FUNDAMENTAL VOLTAGE

$E$  = EFFECTIVE VALUE OF DISTORTED VOLTAGE

$$E^2 = E_F^2 + E_H^2$$


$$E = \sqrt{E_F^2 + E_H^2}$$

$$\text{TOTAL HARMONIC DISTORTION (THD)} = \frac{E_H}{E_F}$$



ph

A SQUARE WAVE HAS AN AMPLITUDE OF 66 V. THE FUNDAMENTAL IS 84 V.


- CALCULATE
- THE EFFECTIVE VALUE OF SQUARE WAVE
  - EFFECTIVE VALUE OF FUNDAMENTAL
  - TOTAL HARMONIC DISTORTION



$(E) = \text{EFFECTIVE VALUE} = 66V$



SCOPE



$$E_F = \frac{E_{MAX}}{\sqrt{2}} = \frac{84}{\sqrt{2}} = 59.4V$$

$$E^2 = E_F^2 + E_H^2$$

$$66^2 = 59.4^2 + E_H^2$$

$$E_H = \sqrt{66^2 - 59.4^2} = 28.8V$$

$$THD = \frac{E_H}{E_F} = \frac{28.8}{59.4} = 0.48$$



