


Les

## CORONA

CORONA FORMS WHEN THE VOLTAGE OF A CONDUCTOR PASSES THE DISRUPTIVE CRITICAL VOLTAGE. THIS OCCURS ON EACH CONDUCTOR AT EVERY HALF CYCLE AND CONTRIBUTES A TRIPLE HARMONIC TO THE CHARGING CURRENT.

## DISRUPTIVE CRITICAL VOLTAGE

BREAK DOWN STRENGTH OF AIR AT 76 cm PRESSURE  
 25°C IS  $30 \text{ kV/cm}$  (OR)  $21.1 \text{ kV(RMS)/cm}$   
 (PEAK)




SPHERE TEST



$$\delta = \frac{3.92 b}{273 + T}$$

$b$  = BAROMETRIC  
PRESSURE OF  
MERCURY



VISUAL CRITICA

$E_g$  = BREAK DOWN VOLTAGE TO NEUTRAL

$$E_g = m \delta g_b r \ln \frac{D}{r}$$


$$g_b = 21.1$$

$r$  = RADIUS OF CONDUCTOR

$m = 1.0$  FOR SMOOTH WIRE

0.93 FOR ROUGHENED (OR) WEATHERED WIRE

0.87 STRANDED WIRE




VISUAL CRITICAL VOLTAGE =  $E_v = 21.1 \text{ m} \delta r \left( 1 + \frac{0.3}{\sqrt{\delta r}} \right) \ln \frac{D}{r}$

KV RMS  
TO NEUTRAL

### DISADVANTAGE OF CORONA

- POWER LOSS
- INTERFERENCE TO TELECOMMUNICATION SYSTEM.

### AVOIDANCE OF CORONA




TO AVOID THE CORONA, THE DISTANCE BETWEEN CONDUCTOR NEEDS TO BE INCREASED TO INCREASE THE DISRUPTIVE CRITICAL VOLTAGE.

BUT SUCH DISTANCE IS LIMITED BY COST.

IN PRACTICAL, HOLLOW CONDUCTORS ARE UTILIZED  
STEEL CORE, ALUMINIUM STRANDED

CONDUCTORS → INCREASE THE STRENGTH  
→ REDUCE THE POSSIBILITY  
FOR CORONA

# SHORT CIRCUIT CURRENT OF ALTERNATOR



$$i_{sc} = A e^{-\frac{Rt}{L}} + B$$


$$A = \frac{E}{\sqrt{R^2 + \omega^2 L^2}}$$

$$\sin\left(\theta - \tan^{-1} \frac{\omega L}{R}\right)$$





↑  
POWER FACTOR  
ANGLE

$$B = \frac{E}{\sqrt{R^2 + \omega^2 L^2}} \sin\left(\omega t + \theta - \tan^{-1} \frac{\omega L}{R}\right)$$

$$\omega = 2\pi f$$



# CURRENT LIMITING REACTOR



$$X = \frac{(n-3)}{2n} \times G$$

$n > 3$

$n$  = NUMBER OF SECTION


$G$  = % INDUCTIVE REACTANCE  
OF GENERATOR

$X$  = % INDUCTIVE REACTANCE  
OF REACTOR

# VOLTAGE TRANSIENTS AND LINE SURGES

$$X_L = 2\pi f L$$



$$X_C = \frac{1}{2\pi f c}$$



$$Z = \sqrt{R^2 + (X_L - X_C)^2}$$

POWER LINE RESONANCE PRODUCES LINE VOLTAGE SURGE

AIR




$$f_r \rightarrow X_C = X_L$$

$Z = \text{MINIMUM}$


$$I = \frac{E}{Z} \rightarrow I = \text{MAX}$$

## CAUSE OF LINE SURGE

- (1) RESONANCE
- (2) SWITCHING
- (3) INSULATION FAILURE
- (4) ARCING TO EARTH
- (5) LIGHTNING STRIKE




WAVE AT (AA)



WAVE AT (XX)

LINE SURGE CAN DAMAGE THE EQUIPMENTS. THE NATURE OF SURGE

THE ORIGIN OF LINE SURGE AND PROTECTION SYSTEM NEEDS TO  
APPLY IN POWER SYSTEM.



$L =$

$C =$

SWITCHING VOLTAGE

SWITCHING EMF VELOCITY

$$v = \frac{1}{\sqrt{LC}}$$

LIGHT  
VELOCITY

$3 \times 10^{10}$  cm/s

L = INDUCTANCE

C = CAPACITANCE OF LINE

SWITCHING CURRENT

$$i = \frac{E}{\sqrt{C/L}} = \frac{E}{Z}$$

$$Z = \sqrt{\frac{L}{C}}$$

LINE IMPEDANCE

Z = SWITCHING IMPEDANCE

$$L = 4 \ln \frac{D}{r} \times 10^{-6} \text{ H/cm} \quad (\text{SURGE IMPEDANCE})$$

$$C = \frac{1}{4 \ln \frac{D}{r}} \text{ MF/cm}$$

400 → 600 Ω (OVERHEAD LINE)

40 → 600 Ω (CABLE)

$$E = E + E$$

PROBLEM

A TRANSMISSION LINE HAS  $0.0128 \mu\text{F}$  CAPACITANCE AND  $1.9 \text{ mH}$  INDUCTANCE.

IT IS JOINED WITH A CABLE  $0.34 \mu\text{F}$  CAPACITANCE AND  $0.25 \text{ mH}$  INDUCTANCE.

CALCULATE (a) NATURAL IMPEDANCE OF O.H. LINE

(b) NATURAL IMPEDANCE OF U.G. CABLE

(c) REFLECTED CREST VOLTAGE

(d) MAXIMUM VOLTAGE AT JUNCTION



LINE VOLTAGE =  $50 \text{ kV}$

# VOLTAGE SURGE & PROTECTION

$$P_{\text{PRODUCED}} = P_{\text{ABSORBED}} + P_{\text{LOSSES}}$$

GENERATOR

LOAD




PROTECTION

ARcing Horn

LIGHTNING ARRESTER

SURGE ABSORBER

# CALCULATION OF VOLTAGE SURGE



$$i' = \frac{Z_B - Z_A}{Z_B + Z_A} i$$

$$E' = \frac{Z_B - Z_A}{Z_B + Z_A} E$$

$$Z = \text{NATURAL IMPEDANCE} = \sqrt{\frac{L}{C}}$$

$E''$  = MAXIMUM VOLTAGE AT JUNCTION

$i''$  = MAXIMUM CURRENT AT JUNCTION

$E'$  = REFLECTED CREST VOLTAGE

$E$  = NORMAL SYSTEM VOLTAGE

$Z_B$

OH LINE

FAULT

UG CABLE

REFLECTION SOURCE


$$(a) \text{ OH LINE } Z_B = \sqrt{\frac{L}{C}} = \sqrt{\frac{1.5 \times 10^3}{0.0125 \times 10^{-6}}} = 346.4$$

$$(b) \text{ UG CABLE } Z_A = \sqrt{\frac{L}{C}} = \sqrt{\frac{0.25 \times 10^3}{0.3 \times 10^{-6}}} = 28.9$$

$$(c) E' = \frac{Z_B - Z_A}{Z_B + Z_A} E = \frac{346.4 - 28.9}{346.4 + 28.9} \times 50 = 42.3 \text{ kV}$$

$$(d) E'' = E + E' \\ = 50 + 42.3 \\ = 92.3 \text{ kV}$$

# REFLECTION AT JUNCTION



$$E' = E \left( \frac{\frac{1}{Z} - \frac{1}{Z_1} - \frac{1}{Z_2}}{\frac{1}{Z} + \frac{1}{Z_1} + \frac{1}{Z_2}} \right)$$


$$E'' = E + E'$$

$$i_1'' = \frac{E''}{Z_1}, \quad i_2'' = \frac{E''}{Z_2}$$

ph

10 KV LINE WITH  $700\Omega$  IS CONNECTED TO  $100\Omega$  AND  $200\Omega$  LINES.

CALCULATE (i) REFLECTED VOLTAGE (ii) MAXIMUM VOLTAGE AT JUNCTION  
(iii) MAXIMUM CURRENTS IN BRANCH LINES AND MAIN LINE.



$$I = \frac{E \left( \frac{1}{Z} - \frac{1}{Z_1} - \frac{1}{Z_2} \right)}{\frac{1}{Z} + \frac{1}{Z_1} + \frac{1}{Z_2}}$$

$$= \frac{10,000 \left( \frac{1}{700} - \frac{1}{100} - \frac{1}{200} \right)}{\frac{1}{700} + \frac{1}{100} + \frac{1}{200}}$$

$$E' = -8260V$$

$$E'' = E + E' = 10,000 + (-8260)$$

$$= 1740V$$

$$I_1 = \frac{E''}{Z_1} = \frac{1740}{100} = 17.4 \text{ Amp}$$

$$I_2 = \frac{E''}{Z_2} = \frac{1740}{200} = 8.7 \text{ Amp}$$

$$I = I_1 + I_2$$

$$= 17.4 + 8.7 = 26.1 \text{ Amp}$$

