


(iii) APPLICATION OF GRADIENT IN POWER ENGINEERING


CALCULATIONS



$$\text{LOAD} / \text{UNIT AREA} = \text{STRESS}$$



$$\text{VOLTAGE STRESS} = \frac{\text{SYSTEM VOLTAGE}}{\text{THICKNESS OF CONDUCTOR}}$$



a = CONDUCTOR RADIUS
 b = OVER ALL RADIUS

FOR CABLE DESIGN

$$b = e \times a$$


$$e = 2.718$$

$$\begin{array}{l} \text{CAPACITANCE} \\ \text{OF} \\ \text{UNDERGROUND} \\ \text{CABLE} \end{array} = \frac{2\pi \epsilon}{\ln \frac{b}{a}} \quad \text{F/km}$$

ϵ = DIELECTRIC CONSTANT

APPLICATION OF COMPLEX NUMBERS

$$1 \mu\text{F} = 10^{-6} \text{ F}$$



TOTAL IMPEDANCE

$$f = 50 \text{ Hz}$$

$$R = \text{RESISTANCE} = 1 \Omega$$


$$L = \text{INDUCTANCE} = 1 \text{ H}$$

$$X_L = \text{INDUCTIVE REACTANCE} = 2\pi f L$$

$$= 2 \times 3.1416 \times 50 \times 1$$

$$= 314.16 \Omega$$

$$\begin{aligned} X_C &= \text{CAPACITIVE REACTANCE} (\Omega) = \frac{1}{2\pi f C} \\ &= \frac{1}{2 \times 3.1416 \times 50 \times 1 \times 10^{-6}} \\ &= \frac{10^6}{314.16} \\ &= 3183 \Omega \end{aligned}$$



$$1 \mu\text{F} = 10^{-6} \text{ F}$$

X_C = CAPACITIVE
REACTANCE
(Ω)


$$\begin{aligned} &= \frac{1}{2\pi fC} \\ &= \frac{1}{2 \times 3.1416 \times 50 \times 10^{-6}} \\ &= \frac{10^6}{314.16} \\ &= 3183 \Omega \end{aligned}$$

$$\begin{aligned} Z &= R + jX_L + (-jX_C) \\ &= 1 + j314.16 - j3183 \end{aligned}$$

$$= 1 - j31515$$

$$Z = \sqrt{1^2 + 31515^2} \angle -\tan^{-1} \frac{31515}{1}$$

$$= 31515.2 \angle -89^\circ \Omega$$



ADDITION, SUBTRACTION, MULTIPLICATION
AND DIVISION OF COMPLEX
NUMBERS

Ex CALCULATE

$$(a) (3 + j4) + (4 - j7)$$

$$(b) (3 + j7) - (3 - j11)$$

$$(c) (3 + j4)(1 + j2)$$

$$(d) (3 + j4)(1 - j2)$$

$$(e) \frac{3 + j4}{4 + j3}$$

$$(f) \frac{4 + j3}{4 - j3}$$

$$(a) (3 + j4) + (4 - j7)$$

$$= 3 + 4 + j4 - j7$$

$$= 7 - j3$$

$$= \sqrt{7^2 + 3^2} \angle -\tan^{-1} \frac{3}{7}$$

$$= 7.615 \angle -\tan^{-1} 0.428$$

$$= 7.615 \angle -23.17^\circ$$

$$(b) (3 + j7) - (3 - j11)$$

$$3 + j7 - 3 + j11$$

$$0 + j18$$

$$18 \angle 90^\circ$$

$$(c) (3+j4)(1+j2)$$

METHOD (1)

$$\boxed{z_1 \angle \theta_1 \times z_2 \angle \theta_2 = z_1 z_2 \angle \alpha_1 + \alpha_2}$$

$$\frac{z_1 \angle \theta_1}{z_2 \angle \theta_2} = \frac{z_1}{z_2} \angle \alpha_1 - \alpha_2$$

$$\left(\sqrt{3^2+4^2} \angle \tan^{-1} \frac{4}{3} \right) \times \left(\sqrt{1^2+2^2} \angle \tan^{-1} \frac{2}{1} \right)$$

$$5 \angle \tan^{-1} 1.333 \times 2.236 \angle 63.4$$

$$5 \angle 53.1 \times 2.236 \angle 63.4$$

$$11.18 \angle 53.1 + 63.4$$

$$11.18 \angle 116.5$$

$$a + jb = \sqrt{a^2+b^2} \angle \tan^{-1} b/a$$

$$a - jb = \sqrt{a^2+b^2} \angle -\tan^{-1} b/a$$


METHOD (2)

$$(3+j4)(1+j2)$$

$$\begin{array}{c} 3+j4 \\ \times \\ 1+j2 \end{array}$$

$$\begin{array}{r} 3+j4 \\ j6-8 \\ \hline 3+j10-8 \end{array}$$

$$= -5 + j10$$



$$= \sqrt{5^2+10^2} \angle 180 - \tan^{-1} \frac{10}{5}$$

$$= 11.18 \angle 180 - \tan^{-1} 2$$

$$= 11.18 \angle 180 - 63.43 = 11.18 \angle 116.5$$

$$j \times j = -1$$

$$(d) \frac{(3+j4)(1-j2)}{}$$

$$\left(\sqrt{3^2+4^2} \angle \tan^{-1} 4/3 \right) \times \left(\sqrt{1^2+2^2} \angle -\tan^{-1} 2/1 \right)$$

$$\angle 53.1 \times 2.236 \angle -63.4$$

$$11.18 \angle -10.3$$

$$(e) \frac{3+j4}{4+j3}$$

$$\frac{\sqrt{3^2+4^2} \angle \tan^{-1} 4/3}{}$$

$$\frac{\sqrt{4^2+3^2} \angle \tan^{-1} 3/4}{}$$

$$\frac{\sqrt{25} \angle \tan^{-1} 1.333}{}$$

$$\sqrt{25} \angle \tan^{-1} 0.75$$

$$\frac{\angle 53.1}{\angle 36.8} = \angle 53.1 - 36.8$$

$$\angle 16.3$$

$$(f) \frac{4+j3}{4-j3}$$

$$\frac{\sqrt{4^2+3^2} \angle \tan^{-1} 3/4}{}$$

$$\frac{\sqrt{4^2+3^2} \angle -\tan^{-1} 3/4}{}$$

$$\frac{\sqrt{25} \angle \tan^{-1} 0.75}{}$$

$$\sqrt{25} \angle -\tan^{-1} 0.75$$

$$\angle 36.8$$


$$\angle -36.8$$

$$\angle 36.8 - (-36.8)$$

$$\angle 73.6$$

APPLICATION OF EQUATIONS AND FORMULA IN POWER ENGINEERING CALCULATIONS

SAG OF TRANSMISSION LINE




$$SAG = \frac{W l^2}{8T}$$

W = WEIGHT OF CONDUCTORS (N/m)

l = LINE SPAN (DISTANCE BETWEEN ADJACENT TOWERS)
(m)

T = TENSION IN CONDUCTOR
(N)


Ex A TRANSMISSION LINE HAS 200 m SPAN BETWEEN SUPPORTS. THE CONDUCTOR WEIGHT IS 10 N/m AND TENSION IN CONDUCTOR IS 11.5 kN . CALCULATE SAG.



$$S_{AG} = \frac{w l^2}{8 T} = \frac{10 \times (200)^2}{8 \times 11.5 \times 10^3}$$

$$= 4.35 \text{ m}$$


(ii) APPLICATION OF GEOMETRIC MEAN
AND LOGARITHM IN POWER ENGINEERING
CALCULATIONS



$ab, bc, ca =$ DISTANCE BETWEEN CONDUCTORS.

GMD = GEOMETRIC MEAN DISTANCE

$$GMD = \sqrt[3]{ab \times bc \times ca}$$



EX

3 ϕ 66 KV TRANSMISSION
LINE IS DELIVERING 2 MW
LOAD AT PF 0.95 PF LAGGING.
LINE CONDUCTORS HAVE 12.5 mm.

THE DISTANCE BETWEEN THEM
ARE 1.5 m, 2 m, 3 m.

THE LINE IS 300 km LONG

LINE RESISTANCE IS
0.06 Ω /km

CALCULATE TOTAL

$$L = 0.09 + 0.46 \log \frac{GMD \text{ OF CONDUCTORS (GMD)}}{RADIUS \text{ OF CONDUCTORS (r)}}$$

LINE INDUCTANCE (mH/km)

LINE INDUCTIVE REACTANCE AND CAPACITIVE REACTANCE AT 50 Hz.

$$C = \frac{0.241}{\log \frac{GMD}{r}} \quad \mu F / km$$

$$C \cdot SA = 12 \text{ Sg mm}$$

$$\pi r^2 = C \cdot SA$$

$$r = \text{radius} \quad \pi = 3.1416$$

$$3.1416 \times r^2 = 12$$

$$r = \sqrt{\frac{12}{3.1416}} = 1.954 \text{ mm}$$

$$GMD = \sqrt[3]{1.5 \times 2 \times 3} = 2.08 \text{ m}$$

$$L = 0.05 + 0.46 \log \frac{GMD}{r} \quad (\text{mH/km})$$

$$= 0.05 + 0.46 \log \frac{2.08}{1.954 \times 10^3}$$

$$= 0.05 + 0.46 \log \frac{2.08 \times 10^3}{1.954} = 1.44 \text{ mH/km}$$

$$L_{\text{Total}} = 1.44 \times 10^{-3} \text{ mH/km} \times 300 \text{ km} = 0.432 \text{ H}$$

$$X_L = 2\pi fL = 2 \times 3.1416 \times 50 \times 0.432 = 135.7 \Omega$$

$$C = \frac{0.241}{\log \frac{aMD}{r}} \text{ pF/km}$$

$$= \frac{0.241}{\log \frac{2.08 \times 10^3}{1.954}} = 0.00798 \text{ pF/km}$$

$$C_{\text{Total}} = 0.00798 \times 300 = 2.39 \text{ pF}$$

$$X_C = \frac{1}{2\pi fC} = \frac{1}{2 \times 3.1416 \times 50 \times 2.39 \times 10^{-6}} = \frac{10^6}{2 \times 3.1416 \times 50 \times 2.39} = 1333 \Omega$$

